



Neighborhood Stabilization

Technical Specifications

CABINET SPECIFICATIONS

REVISED

Date of Issue: April 14, 2010

Section 065000 – Cabinets and Countertops

1.1 Section Requirements –

- Cabinet manufacturer must be certified by KCMA.
- All face frames shall be ¾” x 1-1/2” solid select **OAK, MAPLE, or CHERRY.**
- Exterior sides, backs, and bottoms shall be minimum 3/8” thick **PLYWOOD.**
- Drawer box construction shall be ¾” thick all wood drawer sides and back, with clear topcoat. Joints must be dovetail construction, with built in drawer stop.
- Drawer hardware shall be self closing epoxy-coated guides, double roller for smooth action. Rated at 100lbs capacity per drawer.
- Drawer box dimensions shall be a minimum of 21” deep for kitchen and 18” deep for bathrooms.
- Wall cabinets 30” to 42” high must have minimum 5/8” thick, fully-adjustable shelves.
- All wall cabinets, base cabinets, and vanities must have raised panel doors.
- Base cabinets must have recessed toe space, with matching stained toe-kick cover and matching quarter round provided by cabinet supplier.
- Exterior stain color can be selected from manufacturer’s standard finishes that include maple, cherry, and oak, upon final NSP approval. However, a “natural” stain color is NOT acceptable for the NSP.
- All drawers and doors shall have a brushed chrome (or to match existing finishes) single knob pulls.