

Fire permits will be required for fire alarm installations and alterations. Fire alarm drawings shall be to scale and contain the following information:

1. Address of protected premises
2. Owner of protected premises
3. Applicable codes, standards, and other design criteria to which the system is required to comply
4. Type of building construction and occupancy
5. Annunciator location(s)
6. Type of fire alarm system to be provided
7. Calculations, for example, secondary supply and voltage drop calculations
8. Type(s) of fire alarm-initiating devices, supervisory alarm-initiating devices, and evacuation notification appliances to be provided
9. Intended area(s) of coverage
10. Complete list of detection, evacuation signaling, and annunciator zones
11. Complete list of fire safety control functions
12. Candela rating of each visual notification device
13. If ceiling mount devices are used-provide ceiling height.