

STRAIGHT ENDWALLS

DIMENSIONS					BAR SCHEDULE				
PIPE SIZE	L	H	X	Y	BAR	SIZE	LENGTH	NO. REQ.	SPACE
60"	32'-0"	7'-2"	1'-3"	2'-3"	A	6	4'-2"	48	8"
					B	4	31'-8"	17	
					C	6	9'-9"	32	10"
					D	4	7'-10"	18	18"
					E	6	2'-6"	4	
					F	6	1'-6"	4	
66"	34'-0"	7'-8"	1'-3"	2'-8"	A	6	4'-7'	51	8"
					B	4	33'-8"	17	
					C	6	10'-3'	34	10"
					D	4	8'-4"	20	18"
					E	6	2'-6"	4	
					F	6	1'-6'	4	
72"	36'-0"	8'-3"	1'-4"	3'-1"	A	6	5'-1"	54	8"
					B	4	35'-8"	17	
					C	6	10'-11"	36	10"
					D	4	8'-11"	22	18"
					E	6	2'-6"	4	
					F	6	1'-6"	4	
78"	38'-0"	8'-10"	1'-4"	3'-8"	A	6	5'-8"	57	8"
					B	4	37'-8"	17	
					C	6	11'-6"	38	10"
					D	4	9'-6"	22	18"
					E	6	2'-6"	4	
					F	6	1'-6"	4	

ESTIMATED QUANTITIES		
PIPE SIZE	CONC. (CU. YDS.)	STEEL (LBS.)
60"	13.58	1247
66"	15.44	1392
72"	17.63	1563
78"	20.07	1733

DIMENSIONAL AND QUANTITATIVE DATA FOR 60"-78" CONC. PIPE ENDWALLS	<i>CITY OF JACKSONVILLE STANDARD</i>	N.T.S.	PLATE D-407
		DATE DRAWN	5-9-79
		REVISED DATE	5-12-94