



All bars, bolts, nuts and washers are to be galvanized steel.  
 Bolts diameter shall be 3/8" for 15" to 36" pipe and 5/8" for 42" to 72" pipe.  
 Two connectors required per joint, located 60° right and left of bottom center of pipe.  
 Bolt holes in pipe shell are to be drilled.

CONNECTOR DETAIL  
 FOR MITERED END  
 SECTION

*CITY OF  
 JACKSONVILLE  
 STANDARD*

N.T.S.

PLATE D-436

DATE DRAWN 06/22/89

REVISED DATE 5-12-94