



**SWALE SECTION
20' PAVING**

NOTE:

1. SOIL ANALYSIS MAY INDICATE THE NEED FOR THICKER BASE COURSES THAN THOSE SHOWN HEREIN. THE PAVEMENT THICKNESS SHOWN HEREIN ARE NOT INTENDED TO BE ABSOLUTE, BUT ARE PRELIMINARY CRITERIA & MAY BE MODIFIED TO ACCOMMODATE THE BEARING CAPACITIES OF VARIOUS SUBGRADES.
 2. ALL DISTURBED AREAS SHALL BE SEEDED & MULCHED. ALL AREAS WHERE SOD HAS BEEN DISTURBED OR REMOVED SHALL BE RESODED TO SATISFACTION OF OWNER.
 3. ALL ASPHALTIC CONCRETE SHALL MEET THE REQUIREMENTS OF SECTION 331 AND/OR SECTION 333, F.D.O.T. STANDARD SPECIFICATIONS, LATEST EDITION.
 4. Slopes to be Min. 3:1 and Max. 6:1
- *. OR IN ACCORDANCE WITH APPROVED CONSTRUCTION PLANS.

RESIDENTIAL
60' R/W MIN.
RURAL

*CITY OF
JACKSONVILLE
STANDARD*

N.T.S.

PLATE P-101

DATE DRAWN 2-21-89

REVISED DATE 9/5/03