



SWALE SECTION
56' PAVING W/MEDIAN

MEDIAN MAY BE PAINTED OR GRASSED.
 CITY STD., D.O.T. STD., OR D.O.T. TYPE
 "E" CURB MAY BE USED.

1-1/2" ASPHALTIC CONCRETE TYPE S-I OR S-III 1500 L.B. MARSHALL
 8" COMPACTED LIMESTONE BASE MIN. L.B.R. 75, 100% MAX. DENSITY A.A.S.H.T.O. T-180
 12" CONSTRUCTED SUB-BASE MIN. L.B.R. 40, MAX. PLASTIC INDEX OF 6, COMPACTED TO 98% MAX. DENSITY A.A.S.H.T.O. T-180

NOTE:

1. SOIL ANALYSIS MAY INDICATE THE NEED FOR THICKER BASE COURSES THAN THOSE SHOWN HEREIN. THE PAVEMENT THICKNESS SHOWN HEREIN ARE NOT INTENDED TO BE ABSOLUTE, BUT ARE PRELIMINARY CRITERIA & MAY BE MODIFIED TO ACCOMMODATE THE BEARING CAPACITIES OF VARIOUS SUBGRADES.
2. ALL DISTURBED AREAS SHALL BE SEEDED & MULCHED. ALL AREAS WHERE SOD HAS BEEN DISTURBED OR REMOVED SHALL BE RESODED TO SATISFACTION OF OWNER.
3. ALL ASPHALTIC CONCRETE SHALL MEET THE REQUIREMENTS OF SECTION 331, F.D.O.T. STANDARD SPECIFICATIONS, LATEST EDITION.

*. OR IN ACCORDANCE WITH APPROVED CONSTRUCTION PLANS.

INDUSTRIAL
 OR COLLECTOR
 100' R/W MIN.

CITY OF
JACKSONVILLE
STANDARD

N.T.S.	PLATE P-106
DATE DRAWN	3-8-89
REVISED DATE	9/5/03